

Note: roof covering & underlayment as req'd by code.

Note: Spline to be of material conforming to DOC PS2, min thickness 7/16".

8d box (0.113) nails @ 3" o.c. both sides of panel joint or equivalent. Top side of panel only.

R-Control SIP.

Spline.

R-Control Wood Screw, see SIP-135 for spacing requirements.

R-Control Do-All-Ply 1/2" diameter continuous bead.

SIP Tape or equivalent vapor retarder located interior or exterior per climate conditions or code requirement.

2X Blocking lag screwed to top chord of steel joist.

Structural support member (steel joist).

Design as req'd by engineer. Predrill flange for screw application.

## SECTION

Scale: NTS

Updated 1-16-12

R-Control® SIP

TITLE: Surface Spline (Top)  
At Steel Joist

NO.  
SIP-133e